is not used in the thermal power plant industry.

(b) The coal supplied in India for power generation, has as ash content which varies from 35 to 49 per cent.

(c) Department of Coal is required to coordinate with Coal India Ltd. and to take appropriate steps to minimise the problem of the variation in the quality of coal from different coal mines. Coal supply contracts are being evolved to have a better control on coal quality in future.

(d) The land covered for ash disposal will depend upon the capacity of the power plant, ash context an the number of years of operation and varies from station to station.

(e) The Government is aware of the problem of land coverage which may result due to dumping of ash from thermal power stations. Appreciable amount of developmental work has been carried out to find variety of uses for the ash which includes reclaimation of waste land. as a constituent of cement, building and road matetrial, back filling of abandoned mines and as a fertilizer etc.

विद्युत उत्पादन के लिये प्रतिष्ठापित क्षमता का उपयोग न किया जाना

2752. **चौधरी हरमोहन सिंह :** क्या **विद्युत** मंत्री यह बताने की कृपा करेंगे कि

(क) क्या यह सच है कि विद्युत उत्पादन की प्रतिष्ठापित क्षमता का केवल 54 प्रतिशत ही इस्तेमाल किया जा रहा है जिसके फलस्वरूप राज्यों को बिजली संकट का सामना करना पड़ रहा है, और

(ख) यदि हां, तो पूरी प्रतिष्ठापित क्षमता का इस्तेमाल न किये जाने के क्या कारण है ?

विद्युत मंत्रालय में राज्य मंत्री (श्री पी. वी. रंगैया नायडू): (क) और (ख) अप्रैल, 1993 से फरवरी, 1994 को अवधि के दौरान, देश में ताप विद्युत केन्द्रों का संयंत्र भार अनुपात, वर्ष 1990–91 के दौरान 54 प्रतिशत की तुलना में 68.2 प्रतिशत था । जल विद्युत और गैस केन्द्रों से विद्युत उत्पादन, जल, गैस और प्रणाली भार सम्बन्धी स्थितियों की उपलब्धता पर निर्भर करता है । देश में अधिष्ठापित क्षमता के ईष्टतम समुपयोजन के लिए किए जा रहे विभिन्न उपायों में ये शामिल हैं, पुरानी यनिटों का नवीकरण और आधुनिकीकरण करना, संयंत्र सुधार कार्यक्रमों को हाथ में लेने हेतु विद्युत बोर्डों की सहायता करना, अपेक्षित गुणवत्ता वाले कोयले की अपेक्षित मात्रा में सप्लाई करना, प्रचालन और रख-रखाव में कार्यरत कार्मिकों को प्रशिक्षण देना और पारेषण एवं वितरण प्रणाली को सशक्त करना । जबकि ताप विद्युत संयंत्रों का क्षमता समुपयोजन बढ़ रहा है, तथापि कमी बनी हुई है क्योंकि निधियों मे कमी होने के कारण नयी उत्पादन क्षमता प्रतिबंधित की गयी है । जहां निधियों की कमी ने नवीकरण और आधुनिकीकरण कार्यक्रमों के क्रियान्वयन को प्रभावित किया है वहीं संयंत्रों के समयानुसार रखरखाव में को भी प्रभावित किया है ।

Revival package for the sick mills of NTC

2753. MISS SAROJ KHAPARDE: Will the Minister of TEXTILES be pleased to state:

(a) what are the details of the proposed National Textile Corporation's revival package for its sick units;

(b) whether all the Trade Unions in the country have refused to accept the terms of the revival packags and are agitating on this issue; and

(c) if so, what action Government propose to take in the matter?